

Edition 1: November 30, 1989; Application No LR 17773-25 - Rexdale
Issued by I. Soni, P. Eng

Contents: Pages - 1 to 7
Figures - 1 to 2
Ills - 1 to 3

SUBJECT

CLASS 2252 01 - PROCESS CONTROL EQUIPMENT

Capacitance type, continuous level control, Silomaster Cap - Level II, Series CL, rated 240V ac or 120V ac or 24V ac (+/- 15 percent), 50/60Hz, 7.5VA; output 4-20mA; control relay contacts 115V ac, 3A res; ambient temperature 55C max, CSA Enclosure 4.

Note: Suffix letters and digits indicating relays, input voltage, probe details, etc. are added to the series designation to form the complete model number.

Edition 1: January 29, 1990; Application No LR 17108-32 - Rexdale
Issued by G. Shprintsen, P. Eng.

Contents: Pages - 1 to 8
Figures 1 to 27

SUBJECT

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Groups C and D:

Silomaster Cap-Level II, Continuous Level Control, Series CL, with integral capacitance probe (fully insulated with PFA), input 120/240V ac or 24V ac (± 15 percent), 50/60Hz, 7.5VA; output 4-20mA; contacts dpdt, rated 115V ac, 3A resistive.